





Slika 1.3. Merenje otpornosti strujnim spojem U/I metode



Slika 1.3. Merjenje otpornosti strujnim spojem U/I metode



Slika 1.3. Merjenje otpornosti strujnim spojem U/I metode

| U | V | 1 | 2 | 3 | 4 | 5 | 6 |
|-----------|----------|------|------|------|------|------|------|
| I_1 | mA | 1.0 | 1.9 | 2.8 | 3.8 | 4.7 | 5.8 |
| R_{X1m} | Ω | | | | | | |
| I_2 | mA | 5.2 | 11.6 | 17.2 | 22.8 | 28.4 | 34.0 |
| R_{X2m} | Ω | | | | | | |
| I_1 | mA | 30 | 55 | 85 | 115 | 145 | 180 |
| R_{Y1m} | Ω | | | | | | |
| I_2 | mA | 0.25 | 0.50 | 0.75 | 1.00 | 1.25 | 1.55 |
| R_{Y2m} | Ω | | | | | | |

Tabela 1.3 Rezultati merenja otpornosti strujnim spojem U/I metode

| | | | R_{X1} | R_{X2} | R_{Y1} | R_{Y2} |
|---|--------------------------------|----------|----------|----------|----------|----------|
| Korišćeni opseg voltmetra V | U_{\max} | V | 6 | 6 | 6 | 6 |
| Klasa tačnosti voltmetra V | kl_V | % | 1 | 1 | 1 | 1 |
| Korišćeni opseg ampermetra A | I_{\max} | mA | 10 | 40 | | |
| Klasa tačnosti ampermetra A | kl_A | % | 0.5 | 0.5 | | |
| Unutrašnja otpornost ampermetra A | R_A | Ω | 320 | 20 | | |
| Maksimalna relativna greška poznavanja R_A | $\frac{\Delta R_A}{R_A}$ | % | +/-1 | +/-1 | | |
| Korišćeni opseg multimetra A_0 | $I_{0\max}$ | mA | | | 250 | 2.5 |
| Klasa tačnosti multimetra A_0 | kl_{A0} | % | | | 3 | 3 |
| Unutrašnja otpornost multimetra A_0 | R_{A0} | Ω | | | 1.2 | 98.2 |
| Maksimalna relativna greška poznavanja R_{A0} | $\frac{\Delta R_{A0}}{R_{A0}}$ | % | | | +/-1 | +/-1 |

Tabela 1.4. Vrednosti karakteristika mernih instrumenata za strujni spoj U/I metode